



TYPE APPROVAL CERTIFICATE 1105 WITH REGULATION ON PRODUCTION CONTROL

KEYWORD: VENTILATION
Ventilation ducts and details

BBR 1, 5, 6
BSAB: QL

Certificate holder

LINDAB VENTILATION AB, Grevie, SE - 269 82 BÅSTAD
Tel.: +46 431-850 00, Fax: +46 431-853 25
E-mail: lennart.porss@lindab.se, Web site: www.lindab.com

LINDAB SAFE® and LINDAB SAFE® CLICK – Ventilation ducts and details

Round helical locked sheet metal ducts and details/ parts of ducts, manufactured from galvanised sheet steel. If requires higher corrosivity categories, the ducts can be supplied in stainless steel.

The parts are joined with screws or blind rivets respective notches, click-system. The seal is created by using a ring-shaped sealing of the double-lip type.

Application/Intended use

Distribution of ventilation air.

Approval

The product is approved with respect to the following paragraphs in the Swedish Building Regulations (BBR):

Construction products with confirmed properties	1:4
Fire protection, Air handling installations (Material)	5:526
Ventilation (general and air tightness*)	6:25, 6:255

* The ducts system fulfils the requirements for air tightness class D, according to SS-EN 12237

Within the prescribed field of application the product meets the criteria stipulated in PBL Cap. 8, 4§ Regulations governing the technical properties of materials used in construction works:

2. Safety in case of fire
3. Hygiene, health and environment

Appendix 1	Associated documents	12/11/2012
Appendix 2	Product markings	12/11/2012
Appendix 3	Directions on production control	12/11/2012
Appendix 4	Basis of the certificate	12/11/2012

Kiwa Swedcert

Campus Gräsvik 1
371 75 Karlskrona
Sweden
Tel 0455-30 56 00
Fax 0455-104 36
bygg@kiwa.se
www.kiwa.se



1913
PBL

Decision: 2012-11-12

Reg. No: 763/12

Valid until: 2017-11-12

Earlier No: SITAC TG: 1358/88
Proj.No T001088-03

Kiwa Swedcert

Bertil Wolgast
TC

Rozalia Gyarmati
TA